



SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUARTERS
MUGLISARA, SURAT - 395 003

Phone No. 0261 - 2423750 to 56, Fax No. 0261 - 2451935, 0261 - 2422110 M - 097243 45553

To,
The Principal
Gajera International School,
Beside Power Station,
Utran-Surat

SUB: - Inspection of Fire Fighting System installed in Gajera International School,
Beside Power Station, Utran-Surat

Ref: - Your Application on Dt. 13-01-2020

With reference to the above Fire Fighting System installed in the said premises was inspected by this dept. on date: 21 - 03 - 2020.
During inspection, Following system were found adequate & in working condition.

1	Fire Hydrant System With Hose Boxes Hose Reel in working condition	YES
2	Sprinkler system in Basement	YES
3	ABC Type Fire Extinguisher 06 K.G Capacity each	YES
4	CO2 Type Fire Extinguisher 4.5 KG Capacity	YES
5	Main Fire Pump & Jockey Pump with Auto system	YES
6	Fire Service Inlet 2 way	YES
7	Under Ground Water Tank Capacity 50,000 Ltrs	YES
8	Over Head Water Tank Capacity 1,00,000 Ltrs	YES
9	Fire Alarm system	YES
10	Generator	YES
11	Emergency Exit Sign Board	YES

- (01) Fire fighting system to be maintain perfect working condition
- (02) In case of Emergency, Fire Safety system must be operated by your trained person immediately.
- (03) The Fire Dept. of SMC will not be responsible for any loss of life & Property due to Fire/ Emergency Incident inside your premises.
- (04) Trained manpower shall be available for fire Fighting in the premises round the clock.
- (05) Our Fire Certificate to Fire Fighting Systems available in our premises only. You are here by advised to maintain the above system in good working condition
- (06) Any Other instructions given by Fire Dept. from time to time about fire safety of the premises to be Followed.
- (07) This certificate is valid for one year from the date of issue.
- (08) The administrative charges of Rs. 500/- has been recovered vide R. No. 161/3, Dated: 21-03-2020.

A.R. Solanki
6-6-2020
Divisional Officer

FES / NOC / Outward / No.: 51
Date 6/6/2020



16-7-2020
I/C CHIEF FIRE OFFICER
Surat Municipal Corporation